



Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
CalcPts_1	Illuminance	Fc	1.40	7.4	0.0	N.A.	N.A.

Luminaire Schedule										
Symbol	Qty	Label	Description	Arrangement	Total Lamp Lumens	Lum. Lumens	Lum. Watts	LLF		
□	10	AA	LNC3-24L4K-075-4-U	SINGLE	N.A.	5740	59.9	0.900		
□	3	BB	LNC3-24L4K-035-2	SINGLE	N.A.	3145	27.9	0.900		
□	2	CC	ASL-16L-4K-210-3	SINGLE	12674	12674	115	0.900		
□	1	DD	ASL-16L-4K-210-4	SINGLE	12974	12974	115	0.900		

- Standard Reflectance of 80/50/20 unless noted otherwise
- Not a Construction Document, for Design purposes only
- Standard indoor calc points @ 30" A.F.F. unless noted otherwise
- Standard outdoor calc points @ Grade unless noted otherwise
- Mlazgar Associates assumes no responsibility for installed light levels due to field conditions, etc.

#	Date	Comments
Revisions		

RLMA Project #: 57356
Drawn By: BS
Date: 8/10/2017
Scale: 1" = 16'