

## Lenz, Bernard

---

**From:** Anderson, Leland  
**Sent:** Monday, May 4, 2020 10:29 AM  
**To:** Lenz, Bernard  
**Subject:** Emailing: La Crosse #17 Motor Quotation-Revised\_4-14-20.pdf  
**Attachments:** La Crosse #17 Motor Quotation-Revised\_4-14-20.pdf

Bernard,

Here is the quote for repairing or replacing the pump motor at Well 17. Due to the failure of the BMR motor in only 5 years of operation and the fact that La Crosse was the only Municipality in Wisconsin to use this motor for continued use of operations it is my recommendation to replace this motor with a U S Motor. We have been using U S motors in the past and have had very good luck with these motors lasting 25+ years. The BMR motors have mainly been used for irrigation systems out West which are run seasonal and not continuous. Pulling these motors every 5 years or less is not cost effective in our operations. (currently more than \$5,000 to pull and replace the motor).

Lee Anderson  
Water Superintendent  
800 East Avenue N.  
La Crosse WI. 54601  
Work (608) 789-7385  
Cell (608) 498-6616  
Fax (608)789-7396

Your message is ready to be sent with the following file or link attachments:

La Crosse #17 Motor Quotation-Revised\_4-14-20.pdf

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.