



Legislation Details (With Text)

File #: 2567 **Version:** 1 **Name:** BOZA File 2567
Type: Request for Variance **Status:** Approved
File created: 8/31/2016 **In control:** Board of Zoning Appeals
On agenda: 9/21/2016 **Final action:** 9/21/2016
Title: An appeal regarding the requirement that fill around the perimeter of a building shall not be less than one foot below the flood protection elevation and shall extend at least 15 feet beyond the limits of any structure at 1827 Avon St., La Crosse, Wisconsin.
Sponsors:
Indexes: BOZA - Floodplain
Code sections:
Attachments: 1. Application, 2. FPBS Letter, 3. Buffer Map, 4. Buffer List, 5. Decision Sheet, 6. Affidavit of Publication, 7. FP&BS Presentation 9/21/16

Date	Ver.	Action By	Action	Result
9/21/2016	1	Board of Zoning Appeals	GRANTED	Pass

An appeal regarding the requirement that fill around the perimeter of a building shall not be less than one foot below the flood protection elevation and shall extend at least 15 feet beyond the limits of any structure at 1827 Avon St., La Crosse, Wisconsin.