



## Legislation Details

**File #:** 2599      **Version:** 1      **Name:** BOZA File 2599  
**Type:** Request for Variance      **Status:** Approved  
**File created:** 10/23/2017      **In control:** Board of Zoning Appeals  
**On agenda:** 11/15/2017      **Final action:** 11/15/2017  
**Title:** An appeal regarding the requirement that fill around the perimeter of a building shall be not less than one foot below the flood protection elevation and shall extend at least 15 feet beyond the limits of any structures at 1619 Palace St., La Crosse, Wisconsin.  
**Sponsors:**  
**Indexes:** BOZA - Floodplain  
**Code sections:**  
**Attachments:** 1. Variance Application, 2. Building Safety Letter, 3. 100-Foot Buffer List, 4. Buffer Map, 5. Returned Mailing - Resent 11/7/17, 6. FP&BS Presentation 11/15/17, 7. Drawing of Property - Submitted 11/15/17, 8. Photos - Submitted 11/15/17, 9. Decision Sheet, 10. Affidavit of Publication

Date	Ver.	Action By	Action	Result
11/15/2017	1	Board of Zoning Appeals	GRANTED	Pass