



## Legislation Details

---

<b>File #:</b>	2640	<b>Version:</b>	1	<b>Name:</b>	BOZA File 2640
<b>Type:</b>	Request for Variance	<b>Status:</b>		<b>Status:</b>	Approved
<b>File created:</b>	2/5/2020	<b>In control:</b>		<b>In control:</b>	Board of Zoning Appeals
<b>On agenda:</b>	2/19/2020	<b>Final action:</b>		<b>Final action:</b>	2/19/2020

**Title:** An appeal regarding the requirement that fill around the perimeter of a building shall be not less than one foot below the flood protection elevation and shall extend at least 15 feet beyond the limits of any structure at 710 George Street, La Crosse, Wisconsin.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. FP&BS Letter, 2. Variance Application, 3. Buffer Map, 4. 100-Foot Buffer List, 5. Signed Decision Sheet, 6. Affidavit of Publication

Date	Ver.	Action By	Action	Result
2/19/2020	1	Board of Zoning Appeals	GRANTED	Pass