

James Makepeace, P.E.
Makepeace Engineering LLC
200 Mason Street #15
Onalaska, WI 54650

August 12th, 2022

Yuri Nasonovs, Engineer
City of La Crosse
400 La Crosse Street
La Crosse, WI 54601

Mr. Nasonovs,

Regarding the Chilea Institute Addition 3716 Mormon Coulee Road, according to Chapter 105-55, the project does not appear to be subject to post-construction performance standards as follows:

- a. Approximate area of land disturbance, 6,122 sf, is under a quarter acre
- b. Total combined excavation & fill, 235 cy, is under 400 cy
- c. No open trench
- d. The project adds 764 sf of new impervious area, or approximately 3%
- e. Project does not create a new road
- f. Project does not create a new plat

As such, there are no post-construction stormwater standards to be met.

Sincerely,
James Makepeace, P.E.
Makepeace Engineering LLC