

Conditions if excavation in new street is permitted by the BPW:

The Engineering Department recommendation if approving this request would be the requirement of replacing the bituminous pavement a minimum of 8 feet in width from Curb to Curb and sealing the joints with an elastomeric sealant.