

## **Crandall, Jay**

---

**From:** Hassemer, Jamie  
**Sent:** Tuesday, May 21, 2019 2:29 PM  
**To:** Crandall, Jay  
**Subject:** RE:

Jay,

There is a conduit for fiber under the sidewalk between Jay and King.

There is electrical in the boulevard between Jay and Cass.

At King they will cross two electrical lines and a fiber line.

There is signal interconnect under sidewalk between the cans at 5+96 to 8+04 on their plans that they don't  
*SHOW*

At Cass they will cross two electrical lines as well as signal fiber.

From Cass to Cameron there is electrical in boulevard only.

From Cameron south the electrical line is under the front half of the sidewalk.

Let me know if you have any questions.

Thank You,

*Jamie Hassemer*

Civil Engineer I, EIT  
City of La Crosse  
Phone: (608) 789-8182  
Cell Phone: (608) 790-0302  
Email: [hassemerj@cityoflacrosse.org](mailto:hassemerj@cityoflacrosse.org)

---

**From:** Crandall, Jay  
**Sent:** Tuesday, May 21, 2019 1:13 PM  
**To:** Nasonovs, Jurijs; Hassemer, Jamie; Asp, Steve; Graff, Mark  
**Cc:** Lenz, Bernard  
**Subject:**

Hi All,

Please review proposed fiber optics plan and inform me of any conflicts with City utilities. Thanks

**Jay Crandall**

*SUBJECT TO AVOIDING ALL  
LISTED AND NON LISTED CONFLICTS*