



**KRAUS-ANDERSON®**  
Construction Company

## Change Order Request

**Project:** 1923025-02  
La Crosse Center Expansion & Renovation  
400 La Crosse Street  
La Crosse, WI 54601

**COR #** 260.00

**Date:** 9/21/2021

**To: Owner** City of La Crosse  
400 La Crosse Street  
La Crosse, WI 54601

**From:** Kraus-Anderson Construction Company  
151 East Wilson Street, Suite 100  
Madison, WI 53703

**PCO #** 373 - Ballroom Projector Mounts (RFI 486)

Item #	Description	Vendor	Amount
1	Ballroom Projector Mounts (RFI 486)	Video Services, Inc.	(\$1,910.00)
<b>Total For Change Order</b>			<b>(\$1,910.00)</b>

**Approved By:** City of La Crosse

**Signed:** \_\_\_\_\_

**Date:** \_\_\_\_\_

**Submitted By:** Kraus-Anderson Construction Company

**Signed:** *Peter Linsmeier*  
6867371012384A6...

**Date:** 9/26/2021 | 7:17 PM CD

**Accepted By:** I & S Group, Inc.

**Signed:** *Kevin Bills*  
B2D92ADEC16949C...

**Date:** 9/30/2021 | 4:53 AM CD

# Proposal Request



## Video Services Inc.

211 Mohr Drive, Suite 100  
 Mankato, MN 56001  
 (507)625-1650

audio|video|technology *specialists*

TO: Kraus Anderson Construction Company  
 Company

Attn. \_\_\_\_\_

151 E Wilson Street Suite 100  
 Address

Madison, WI 53703  
 City, State Zip

Date 9/10/2021	Project No. 16-19990
Project Information	
La Crosse Center Expansion & Renovation	
La Crosse, WI	

Reason for Change (Check all that Apply)	Proposal Request # <u>VSI PR9</u>
<input type="checkbox"/> Error / Omission	
<input checked="" type="checkbox"/> Changed Condition	
<input checked="" type="checkbox"/> Design Improvement	
<input checked="" type="checkbox"/> Non-Project Change	<input type="checkbox"/> Modified Scope
<input type="checkbox"/> Customer Request	<input type="checkbox"/> Schedule Change
<input type="checkbox"/> _____	

**DESCRIPTION OF PROPOSAL REQUEST:**

After receiving the projector lifts from the 4 months of backorder, we noticed an issue when checking one of the units. There was a warning note stating the lifts only support 35 lbs, but the projector itself is 55 lbs with out the mount and lens. This is the largest lift Chief makes.

Removing the lifts and mounting on an extension pole would provide the correct support and better align the projector with the screen.

**NOTES / JUSTIFICATION OF PROPOSAL:**

We have selected a white projector mount to match the color of the projector.

Restock, Return Freight, and Reinspection Fees are required for these by Legrand/Chief Mfg. due to their operational nature.

MATERIAL AND LABOR BREAKDOWN:	
<b>RESPONSIBLE FOR COST</b> <input type="checkbox"/> VSI <input checked="" type="checkbox"/> Customer <input type="checkbox"/> _____	<b>COST BREAKDOWN</b> MATERIALS: \$ (1,432.00) LABOR: \$ (478.00) SUBTOTAL: \$ (1,910.00) TAX (MATERIALS): \$ - \$ - \$ - \$ - \$ - \$ - <b>TOTAL: \$ (1,910.00)</b>

REQUESTED BY: Brian Rutz, Design Engineer  
 Name, Title

DATE: 9/10/2021

APPROVED BY: \_\_\_\_\_  
 Name, Title

DATE: \_\_\_\_\_

**VSI PR9A Appendix****Video Services Inc.**

211 Mohr Drive, Suite 100  
Mankato, MN 56001  
(507)625-1650

audio|video|technology *specialists*

**TO:** Kraus Anderson Construction Company  
Company

Attn.

151 E Wilson Street Suite 100

Address

Madison, WI 53703

City, State Zip

**MATERIAL DETAIL AND LABOR BREAKDOWN:**

MANUFACTURER	MODEL	DESCRIPTION	QTY	UNIT PRICE	EXT. PRICE
<b>ADD POLE MOUNTS</b>					
CHIEF	CMA345	STRUCTURAL CEILING PLATE	3	\$ 143.64	\$ 430.92
CHIEF	CMS0709W	EXTENSION POLE	3	\$ 148.43	\$ 445.28
CHIEF	VCMUW	PROJECTOR MOUNT	3	\$ 372.78	\$ 1,118.34
LIBERTY	E2-HDSEM-M-05	16' HDMI	3	\$ 51.86	\$ 155.59
<b>REMOVE LIFTS</b>					
CHIEF	SL236FD	SMART-LIFT	-3	\$ 2,049.50	\$ (6,148.50)
CHIEF	SLBUW	RPA INTERFACE BRACKET - WHITE	-3	\$ 76.50	\$ (229.50)
CHIEF	RESTOCK FEE	25% RESTOCK FEE	3	\$ 531.50	\$ 1,594.50
CHIEF	INSPECTION FEE	INSPECTION FEE PER UNIT	3	\$ 250.00	\$ 750.00
				<b>MATERIALS TOTAL:</b>	<b>\$ (1,432.00)</b>
				<b>TAX (MATERIALS):</b>	<b>\$ -</b>
				<b>LABOR:</b>	<b>\$ (478.00)</b>
				<b>TOTAL:</b>	<b>\$ (1,910.00)</b>



# REQUEST FOR INFORMATION

DATE: 8/4/2021 UTC  
RFI #: 486

Kraus-Anderson  
1923025-02 - La Crosse Center Expansion & Renovation

TO: ISG

FROM: Travis Dahl  
Video Services, Inc.

PHONE:  
EMAIL:

PHONE:  
EMAIL: travis.dahl@videoser.com

CC: HJ Martin Ceilings, KA, Kish Electric,  
VSI

DUE BY: 8/9/2021 UTC

SUBJECT: Ballroom Projector Lifts

DRAWING REFERENCE:  
SPEC SECTION:

## QUESTION

After 4 months of backordered projector lifts we finally received them. We did unbox one of them to size everything up to assure that the projectors would fit correctly, and to make sure of no issues before taking to site for installation. An issue we noticed right away was the warning note inside stating that these lifts only support 35lbs. The projector itself is 55lbs without the mount and lens installed. These projector lifts are the largest Chief makes. Should we revisit the Draper model that we proposed or how would you like us to proceed?

SUGGESTION:

## DRAWINGS

## RESPONSES

DATE	FROM (FIRM)	FROM (CONTACT)
August 12, 2021 at 3:56 PM UTC	ISG	Eric Rothwell



# REQUEST FOR INFORMATION

DATE: 8/4/2021 UTC  
RFI #: 486

Kraus-Anderson  
1923025-02 - La Crosse Center Expansion & Renovation

Provide pricing to change to the Chief universal fixed mount with vibration isolation plate and downtube.

---

# Request for Information



## Video Services Inc.

211 Mohr Drive, Suite 100  
 Mankato, MN 56001  
 (507)625-1650

audio|video|technology *specialists*

TO: Kraus Anderson Construction Company  
 Company

Attn. \_\_\_\_\_  
 151 E Wilson Street Suite 100  
 Address

Madison, WI 53703  
 City, State Zip

<b>Date</b> 8/4/2021	<b>Project No.</b> 16-19990
<b>Project Information</b>	
La Crosse Center Expansion & Renovation	
La Crosse, WI	

<b>Subject</b> Ballroom Projector Lifts
<b>Cost Impact</b> POTENTIAL
<b>Schedule Impact</b> POTENTIAL

<b>REQUEST / CLARIFICATION REQUIRED:</b>
<p>Ballroom Projector Lifts:                  After 4 months of backordered projector lifts we finally received them. We did unbox one of them to size everything up to assure that the projectors would fit correctly, and to make sure of no issues before taking to site for installation.</p> <p>An issue we noticed right away was the warning note inside stating that these lifts only support 35lbs. The projector itself is 55lbs without the mount and lens installed.</p> <p>These projector lifts are the largest Chief makes. Should we revisit the Draper model that we proposed or how would you like us to proceed?</p>
<p><b>SUBMITTED BY:</b> <u>Travis Dahl (Project Manager)</u>      <b>DATE:</b> <u>8/4/2021</u></p> <p>Name, Title</p>

<b>RESPONSE:</b>
<p><b>RESPONSE BY:</b> _____      <b>DATE:</b> _____</p> <p>Name, Title</p>

