
DATE SUBMITTED FOR

0/31/23 TENANT REVIEW

5/08/24 TENANT COMMEN 06/18/24 TENANT COMMENT

ELECTRICAL SITE

AB/VM 3140.a



FIRST 3 TIES WITHIN TOP 5" OF

(FOR USE IN LANDSCAPED AREAS

GREATER THAN 4' FROM CURB)

POLE BASE

EXTENDED POLE BASE

"D"

HANDHOLE

— BUSHING(S)

— ANCHOR BOLTS

POLE FINISH

-FINISHED GRADE

FIRST 3 TIES WITHIN TOP 5" OF

(FOR USE IN PAVED VEHICULAR

AREAS AN IN LANDSCAPED AREAS

POLE BASE

WITHIN 4' OF CURB)

— COVER TO MATCH

BOND METAL CONDUIT(S).—

CONDUCTOR AND GROUNDING

1 #6 CU GND -

ELECTRODE CONDUCTOR TO

EQUIP. GROUNDING

3/4"x8'-0" —

COPPERWELD

GROUND ROD

BOLT CENTER -

DIAMETER

LIGHTING NOTES

2" (MIN) AIRGAP SPACE BETWEEN TOP OF CONCRETE CROWN AND

PRIOR TO LUMINAIRE INSTALLATION, VERIFY THAT THE LUMINAIRE

BOTTOM OF POLE BASE PLATE FOR VENTILATION.

CIVIL DRAWINGS.

NUMBER, POSITION OF LAMP SOCKET AND DIRECTION.

FOR THE POLE AND FIXTURE WITH THE ARCHITECT.

LAYOUT PRIOR TO INSTALLATION OF THE CONCRETE BASE.

PROVIDE CROWN ON TOP OF CONCRETE BASE TO COMPLETELY SHED

LOCATE LUMINAIRE ON THE DRAWING; AND VERIFY LUMINAIRE CATALOG

CATALOG NUMBER MATCHES THE CATALOG NUMBER SHOWN ON THE

CONTRACTOR SHALL CONFIRM THE MANUFACTURER STANDARD COLOR


CONTRACTOR SHALL CONFIRM THE LIGHT POLE BASE BOLT PATTERN/

FLUSH POLE BASE

"D"

BOLT CENTER -

DIAMETER



ELECTRICAL SITE PLAN

1"= 20'-0"

ELECTRICAL

UTILITIES ARE NOT INDICATED. PRIOR TO EQUIPMENT AND CONDUIT INSTALLATION, THE CONTRACTOR SHALL COORDINATE EXACT INSTALLATION DETAILS AND MODIFY WORK PLAN ACCORDINGLY TO MEET UTILITY REQUIREMENTS. CORRESPOND WITH UTILITY COMPANY PRIOR TO ANY SITE DEVELOPMENT THAT MAY IMPACT THE INSTALLATION SUCH AS IRRIGATION INSTALLATION, CONCRETE OR ASPHALT INSTALLATION, LANDSCAPING, ETC.

REFER TO GENERAL NOTES ON SHEET E0.0.

REFER TO SPECIFICATIONS ON SHEET E0.1.

REFER TO PHOTOMETRIC SITE PLAN FOR PARKING LIGHTING FIXTURE SCHEDULE.

KEY NOTES

GENERAL NOTES

- √ PROVIDE (2) #10 THWN, (1) #10 GND IN 1" CONDUIT FOR DIRECTIONAL SIGN AND CONNECT. TO CIRCUIT SHOWN VIA TIME CLOCK. DISCONNECT SWITCH SUPPLIED BY MANUFACTURER AND INSTALLED BY ELECTRICIAN. TENANT ELECTRICAL CONTRACTOR TO PROVIDE WIRING AND MAKE FINAL CONNECTION AS REQUIRED. COORDINATE ROUTING OF LANDLORD PROVIDED CONDUIT IN FIELD.
- \langle 2 \rangle PROVIDE ONE (1) 1" CONDUIT FROM MENU BOARD TO PP1 WITH PULL STRING FOR FUTURE.
- PROVIDE ONE (1) 1" CONDUIT FROM DIGITAL ORDER SCREEN TO PP1 WITH PULL STRING. PROVIDE FINAL CONNECTION TO DOS CONTROL BOX AS REQUIRED.
- PROVIDE TWO (2) 1" CONDUITS FROM DIGITAL ORDER SCREEN TO DRIVE-THRU WINDOW WITH PULL STRING. ONE CONDUIT FOR SPEAKER, MICROPHONE, DETECTOR LOOP DATA, AND ONE CONDUIT FOR CAMERA DATA. RUN OUTSIDE OF BUILDING FOOTPRINT. TENANT ELECTRICAL CONTRACTOR TO PROVIDE WIRING AND MAKE FINAL CONNECTION AS REQUIRED. VERIFY ALL REQUIREMENTS WITH EQUIPMENT MANUFACTURER PRIOR TO COMMENCING WORK. COORDINATE ROUTING OF LANDLORD PROVIDED CONDUIT IN FIELD.
- √ PROVIDE ONE (1) 1" CONDUIT FROM MENU BOARD TO PP1 WITH PULL STRING. TENANT ⁾ ELECTRICAL CONTRACTOR TO PROVIDE WIRING AND MAKE FINAL CONNECTION AS REQUIRED. VERIFY ALL REQUIREMENTS WITH EQUIPMENT MANUFACTURER PRIOR TO COMMENCING WORK. COORDINATE ROUTING OF LANDLORD PROVIDED CONDUIT IN FIELD. COORDINATE WITH OWNER AND STARBUCKS REPRESENTATIVE PRIOR TO COMMENCING
- $\left<6\right>$ PROVIDE ONE (1) 1" CONDUIT FOR TENANT FURNISHED DETECTOR LOOP TO OSC/ SPEAKER IN COORDINATION WITH TENANT'S REPRESENTATIVE. TENANT ELECTRICAL CONTRACTOR TO PROVIDE WIRING AND MAKE FINAL CONNECTION AS REQUIRED.
- $\sqrt{_7}$ PROVIDE ONE (1) 1" CONDUIT FROM PRE-ORDER MENU BOARD TO PP1 WITH PULL STRING. TENANT ELECTRICAL CONTRACTOR TO PROVIDE WIRING AND MAKE FINAL CONNECTION AS REQUIRED. VERIFY ALL REQUIREMENTS WITH EQUIPMENT MANUFACTURER PRIOR TO COMMENCING WORK. COORDINATE ROUTING OF LANDLORD PROVIDED CONDUIT IN FIELD. COORDINATE WITH OWNER AND STARBUCKS REPRESENTATIVE PRIOR TO COMMENCING
- 8 PROVIDE ONE (1) 1" CONDUIT FROM PRE-MENU BOARD TO PP1 WITH PULL STRING FOR FUTURE.
- $\left\langle 9\right\rangle$ NOT USED.
- PROVIDE (2) #10 THWN, (1) #10 GND IN 1" CONDUIT FOR MONUMENT SIGN AND CONNECT TO CIRCUIT SHOWN VIA TIME CLOCK. DISCONNECT SWITCH SUPPLIED BY MANUFACTURER AND INSTALLED BY ELECTRICIAN. TENANT ELECTRICAL CONTRACTOR TO PROVIDE WIRING AND MAKE FINAL CONNECTION AS REQUIRED.
- PROVIDE TWO (2) 1" CONDUIT TO PATIO AREA FROM ELECTRICAL PANEL PP1 WITH PULL STRING. CONDUIT SHOWN FOR REFERENCE ONLY.
- COORDINATE LOCATION OF UTILITY TRANSFORMER WITH LOCAL UTILITY COMPANY AND CIVIL DRAWINGS. PROVIDE CONCRETE PAD, AND COORDINATE PAD REQUIREMENTS WITH LOCAL UTILITY COMPANY.
- APPROXIMATE LOCATION OF METER WITH MAIN DISCONNECT AND CT CABINET. REFER TO SINGLE LINE DIAGRAM ON SHEET E2.0 FOR INFORMATION.
- UNDERGROUND SECONDARY ELECTRICAL SERVICE. CONDUIT SHOWN FOR REFERENCE ONLY. COORDINATE WITH CIVIL DRAWINGS AND LOCAL UTILITY COMPANY. SEE SINGLE LINE ON SHEET E2.0 FOR CONDUIT AND CONDUCTOR REQUIREMENTS.
- PROVIDE TWO (2) 4" UNDERGROUND CONDUITS WITH PULL STRING FOR TELEPHONE AND INTERNET. PROVIDE LABELED, END-TO-END PULL STRINGS IN ALL CONDUITS FOR FUTURE USE. REFER TO SHEET E1.0 FOR INFORMATION.
- PROVIDE (1) SPARE CONDUIT TO BE RUN THROUGH FOUNDATION WALL OUT REAR OF BUILDING. REFER TO SHEET E1.0 FOR ADDITIONAL INFORMATION.
- $\langle 17 \rangle$ PROVIDE ONE (1) 1" CONDUIT EMBED IN DRIVE THRU LANE FOR VEHICLE DETECTOR LOOP. CENTER CONDUIT ON SPEAKER POST.
- (18) LANDLORD TO PROVIDE (2) #10 THWN, (1) #10 GND IN 1" CONDUIT AND CONNECT TO CIRCUIT SHOWN VIA TIME CLOCK FOR POWER TO LED LIGHT ON DOS CANOPY AND MENU BOARD. SEE ARCHITECTURAL SHEETS FOR CONDUIT STUB-UP DETAILS AND ADDITIONAL INFORMATION. LANDLORD TO PROVIDE WIRING AND MAKE FINAL CONNECTION AS REQUIRED.
- PROVIDE 2#10 AWG + 1# 10AWG GND IN 1"CONDUIT AND CONNECT TO CIRCUIT SHOWN. CIRCUIT SHALL BE ROUTED THOUGHT TIMECLOCK AND PHOTOCELL FOR CONTROL. SEE DETAIL ON THIS SHEET TO PROVIDE COPPER GROUND ROD AND USE # 6 GROUND CONDUCTOR FROM GROUND ROD TO POLE BASE.
- PROVIDE INLINE FUSE HOLDER FUSED TO MEET BALLAST/DRIVER REQUIREMENTS. INLINE FUSE HOLDER SHALL BE RATED FOR 600VAC, 200kA AND SHALL BE UL LISTED TO MEET BREAKAWAY AND SUBMERSIBILITY REQUIREMENTS.
- PROVIDE 2#8 AWG + 1# 10AWG GND IN 1"CONDUIT AND CONNECT TO CIRCUIT SHOWN. CIRCUIT SHALL BE ROUTED THOUGHT TIMECLOCK AND PHOTOCELL FOR CONTROL. SEE DETAIL ON THIS SHEET TO PROVIDE COPPER GROUND ROD AND USE # 6 GROUND CONDUCTOR FROM GROUND ROD TO POLE BASE.

SITE INTERNET & VOICE SYSTEM NOTES

LANDLORD INITIATED CONNECTIVITY: TELECOMMUNICATION SERVICES WILL BE ORDERED BY STARBUCKS FOR THE SPACE LEASED HOWEVER TO PROVIDE STARBUCKS WITH POINT OF FEED EXHIBITS AND LANDLORD TO COORDINATE INITIAL INSTALLATION OF COMMUNICATION INFRASTRUCTURE WITH LOCAL TELCO OR BROADBAND PROVIDER, INCLUDING THE TERMINATION OF ONT (OPTICAL NETWORK TERMINATION)FIBER AND/OR BROADBAND NODE AT THE MINIMUM POINT OF ENTRY. LANDLORD TO PROVIDE ELECTRICAL CONNECTIVITY FOR POTENTIAL LEC (LOCAL EXCHANGE CARRIER) FIBER NODE OR BROADBAND ROUTER AS WELL AS A BACKBOARD PER LOCAL SPECIFICATION FOR SERVICE TERMINATION AND DEMARCATION POINT PLACEMENT. STARBUCKS WILL REQUIRE AT LEAST FIBER OR BROADBAND SERVICES WITH MINIMUM SPEEDS OF 50X10 MBPS. IN EXCEPTIONAL SITUATIONS, STARBUCKS MIGHT NEED ACCESS TO MOUNT ROOF ANTENNAS.

Lamp										
Symbol	Label	Quantity	/ Manufacturer	Catalog Number	Description	Number Lamps	Filename	Lumens Per Lamp	Light Loss Factor	Wattage
	S1	7	Lithonia Lighting	DSX2 LED P2 35K 80CRI T3M HS	D-Series Size 2 Area Luminaire P2 Performance Package 3500K CCT 80 CRI Type 3 Medium Houseside Shield	1	DSX2 LED P2 35K 80CRI T3M HS.ies	19434	0.95	179.222
	S2	2	Lithonia Lighting	DSX2 LED P1 35K 80CRI T5W HS	D-Series Size 2 Area Luminaire P1 Performance Package 3500K CCT 80 CRI Type 5 Wide Houseside Shield	1	DSX2 LED P1 35K 80CRI T5W HS.ies	12630	0.95	134.502
	S 3	2	Lithonia Lighting	DSX2 LED P1 35K 80CRI T3M EGS	D-Series Size 2 Area Luminaire P1 Performance Package 3500K CCT 80 CRI Type 3 Medium External Glare Shield	1	DSX2 LED P1 35K 80CRI T3M EGS.ies	11479	0.95	134.502
	S4	1	Lithonia Lighting	DSX2 LED P1 35K 80CRI BLC4	D-Series Size 2 Area Luminaire P1 Performance Package 3500K CCT 80 CRI Type 4 Extreme Backlight Control	1	DSX2 LED P1 35K 80CRI BLC4.ies	13164	0.95	134.5
	S5	2	Lithonia Lighting	DSX2 LED P1 35K 80CRI T5W	D-Series Size 2 Area Luminaire P1 Performance Package 3500K CCT 80 CRI Type 5 Wide	1	DSX2 LED P1 35K 80CRI T5W.ies	18594	0.95	134.5
	F1	8	KICHLER	258377-1 MOD#:11251/CP133537	LED WALL CYLINDER	1	11251-photometric-report.ies	574	0.95	14.7
	F2	14	Indy	L4 28LM 27K MVOLT G4 90CRI ZT WD CSS	INDY 4" DIA. 1-LED 4000LM, 90CRI, GEN4 DOUBLE WALL WASH WITH CLEAR SEMI-SPECULAR (CSS) PARABOLIC REFLECTOR, DIFFUSE KICKERS AND FROSTED CONVEX GLASS LENS	1	L4 28LM 27K MVOLT G4 90CRI ZT WD CSS.ies	1590	0.95	28.46
	F3	1	Lithonia Lighting	WDGE1 LED P1 30K 90CRI VW	WDGE1 LED WITH P1 - PERFORMANCE PACKAGE, 3000K, 90CRI, VISUAL COMFORT WIDE OPTIC	1	WDGE1_LED_P1_30 K_90CRI_VW.ies	1030	0.95	10.0002

Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
BLDG ENTRY 2	+	17.4 fc	19.3 fc	13.6 fc	1.4:1	1.3:1
DRIVE THRU ENTRY	ж	15.4 fc	26.5 fc	8.9 fc	3.0:1	1.7:1
DRIVE THRU WINDOW	ж	30.0 fc	30.0 fc	30.0 fc	1.0:1	1.0:1
PARKING & SIDEWALKS	ж	4.1 fc	15.0 fc	1.5 fc	10.0:1	2.7:1
PATIO	ж	14.3 fc	21.0 fc	10.8 fc	1.9:1	1.3:1
PROPERTY LINE	+	0.2 fc	0.6 fc	0.0 fc	N/A	N/A
SERVICE DOOR	ж	9.4 fc	9.4 fc	9.4 fc	1.0:1	1.0:1
STARBUCKS	ж	6.2 fc	30.0 fc	1.0 fc	30.0:1	6.2:1
BLDG ENTRY 1	ж	21.0 fc	21.0 fc	21.0 fc	1.0:1	1.0:1

GENERAL NOTES


. ALL EXTERIOR LIGHTING, WHETHER FREE-STANDING OR MOUNTED ON A STRUCTURE, SHALL BE FULL-CUTOFF.

THE TOWNSHIP RESERVES THE RIGHT TO CONDUCT A POST-INSTALLATION NIGHT TIME INSPECTION TO VERIFY COMPLIANCE WITH TOWNSHIP LIGHTING STANDARDS. IF SAID INSPECTION REVEALS A VIOLATION OF SAID STANDARDS, THE TOWNSHIP SHALL DIRECT CORRECTIVE ACTION, WHICH SHALL BE EXECUTED BY THE PROPERTY OWNER AT NO EXPENSE TO THE TOWNSHIP.

3. POST-APPROVAL ALTERATIONS TO LIGHTING PLANS OR SUBSTITUTIONS FOR APPROVED LIGHTING EQUIPMENT SHALL BE SUBMITTED TO THE TOWNSHIP FOR REVIEW AND APPROVAL PRIOR TO CONSTRUCTION OR INSTALLATION.

LIGHTING SHALL BE CONTROLLED BY TIME CLOCK / PHOTOCELL THAT TURN OFF LIGHTS ONE HOUR AFTER CLOSE OF BUSINESS (10 P.M.)

5. CALCULATIONS ARE BASED ON FIXTURE TYPE SCHEDULED. IF FIXTURE OTHER THAN THOSE SPECIFIED IS PROVIDED THE MANUFACTURER SHALL PROVIDE A DETAILED POINT BY POINT CALCULATION TO VERIFY COMPLIANCE WITH LOCAL STREET LIGHTING GUIDELINES.



1 ELECTRICAL SITE PLAN

1"= 20'-0"



DATE SUBMITTED FOR
10/31/23 TENANT REVIEW
05/08/24 TENANT COMMENT

10/31/23 TENANT REVIEW

↑ 05/08/24 TENANT COMMENTS

↑ 06/18/24 TENANT COMMENTS

↑ 07/30/24 TENANT COMMENTS

SHEET TITLE
PHOTOMETRIC
SITE PLAN

DRAWN BY:
AB/VM

3140.a

ES1.