

WO 111102677
 2"MDPE GAS MAIN INSTALLATION FOR
 SYSTEM UPGRADE PROJECT.
 VICTORY ST/LOSEY BLVD S. INTERSECTION
 HEWITT ST/LOSEY BLVD S. INTERSECTION
 DESIGNER ED PRZYTARSKI 608-780-0151
 ENGINEER JIM FLANAGAN 715-577-0418
 COLOR KEY: YELLOW-INSTALL
 BLUE--RETIRE

I-2"PE EF COUPLING (2)
 I-2"PE BALL VALVE #225126
 I-2x2x2BF FF TEE

I-3" HALF STOP
 I-3"BW CAP

I-2MDPE GAS MAIN

RETIRE A SECTION OF 2"MDPE MAIN
 RETIRE 3"STEEL MAIN
 RETIRE 3" STEEL VALVE #620
 (RECORDS SHOW RETIRED
 ALREADY IN 2018)

I-2x2x2BF FF TEE
 I-2"BF CAP

I-2"PE EF COUPLING

**CAUTION: GAS PROJECT WORK INVOLVES 2
 SYSTEM PRESSURES THE LMAT SYSTEM 2-26PSIG
 AND THE LSAM SYSTEM OPERATING @ 26-66 PSIG.
 WHEN THE PROJECT IS COMPLETED THIS
 PORTION OF THE LMAT WILL BE OPERATING ON
 THE LSAM SYSTEM.
 NOTE:WORK ORDER 110859385 AND SERVICE
 RENEWALS ASSOCIATED WITH THAT WORK
 ORDER NEED TO BE COMPLETED PRIOR TO
 BEGINNING THE SYSTEM PRESSURE CHANGE.**

Request Number: **MAP 5**
 SP Number:
 Segment:
 UCRV..


Work Order Information	
Service Request #	:
Design Number	:
Designer/Planner ID	: W72519
Designer/Planner Name	:
Designer/Planner Ph #	:
Manager Approval	:

Joint Utility	
E:	G:
T:	C:

Design Location	
Division	: La Crosse
County	: La Crosse
City	: LA CROSSE
Address	:
T: 15N	R: 7W S: 16
Map #	: 1644650 WIS Permit :

Electric	
Feeder:	Voltage:
Phase:	Bkup Dev ID:

Gas	
System	: Pressure :
Size	: Material :
Dead End	:
Work Order #	:
Date:	01/17/2024
Sketch:	
Scale:	1" equals 67'



CONSTRUCTION USE ONLY
 NO CHANGES (BUILT AS DESIGNED)
 CHANGES MADE AS INDICATED
 (ALL URD MUST HAVE ACTUAL
 MEASUREMENTS FROM THE FIELD SITE)

RFO _____
 FOREMAN _____ DATE _____
 TEAM LEADER _____

DISCLAIMER: THERE ARE NO REPRESENTATIONS OR WARRANTIES (EXPRESS OR IMPLIED) ABOUT THE ACCURACY OF THIS PRINT. THIS PRINT IS PROVIDED WITH NO CLAIM AS TO PRINT COMPLETENESS, TIMELINESS, ACCURACY OF CONTENT OR USEFULNESS. STATE LAW REQUIRES ANYONE DIGGING, GRADING OR EXCAVATING TO OBTAIN A PRIOR FIELD LOCATE OF ALL UTILITIES; THIS PRINT DOES NOT DISCHARGE THIS REQUIREMENT OR ANY OTHER REQUIREMENT. THE COMPANY AND ITS AFFILIATES ASSUME NO LEGAL RESPONSIBILITY OR LIABILITY FOR THE RECIPIENT'S USE (OR ANY OTHER PARTIES' USE) OF THE PRINT, INCLUDING THE RECIPIENTS INTENDED PURPOSE IN USING THE PRINT. NO COMPANY EMPLOYEE OR OTHER PARTY HAS BEEN AUTHORIZED TO PROVIDE THIS PRINT FOR PLANNING OR ESTIMATING PURPOSES; RELY ON THIS PRINT AT YOUR OWN RISK. BY ACCEPTING THIS PRINT, THE RECIPIENT & ANY OTHER PARTY RECEIVING A COPY OF THE PRINT ACKNOWLEDGES AND AGREES TO THIS DISCLAIMER. For All Field Locates Call 811

THIS DOCUMENT IS XCEL ENERGY CONFIDENTIALS AND PROPRIETARY INFORMATION AND MAY NOT BE REPRODUCED IN WHOLE, OR IN PART, NOR MAY ANY OF THE INFORMATION CONTAINED HEREIN BE DISCLOSED WITHOUT THE CONSENT OF XCEL ENERGY. CONFIDENTIALS AND PROPRIETARY INFORMATION © 2019 XCEL ENERGY INC. | XCEL ENERGY IS REGISTERED TRADEMARK OF XCEL ENERGY INC