Craig, Sondra

From:	Coman, Kyle
Sent:	Thursday, May 1, 2025 2:44 PM
То:	chris@couleeregionlandsurveyors.com; James Makepeace
Cc:	Craig, Sondra
Subject:	Chambers-Markle Farmstead Pre-Plat
Attachments:	Preliminary Plat-REVIEW.pdf

Good afternoon,

Please see review comments below, and the attachment for reference.

- 1. It appears land is not being dedicated; the word "dedicated", and "dedication" might be removed from the Owner's Certificate and Consent of Corporate Mortgagee.
- 2. Please correct the plat name in the Register of Deeds Certificate.
- 3. The City Common Council Certificate might be confusing to approvers. Consider revising to read "Resolved that the Chambers-Markle Farmstead Subdivision of Lot 21..." or similar.
- 4. Please correct language in the Legal Description to read "that I have surveyed, divided and mapped the Chambers-Markle Farmstead subdivision plat..."
- 5. Correct misspelling of the word "from" in the 4th line of the notes describing setbacks.
- 6. Please double check the CSM volume, page, and document numbers listed.
- 7. Ensure the sewer lateral immediately north of the existing driveway will not be crossed by the proposed lot line.
- 8. Add bearing and distance to lot line.
- 9. Trim lines as to not enter monument symbol (I know, I know, very minor but I still like to bring it to your attention).

Thank you, gentlemen and please reach out with any questions or concerns.

Kyle Coman, PLS

City Surveyor & Construction Manager Engineering Department City of La Crosse 400 La Crosse Street La Crosse, WI 54601

comank@cityoflacrosse.org

Office: 608.789.7366 Cell: 608.790.0309

