



La Crosse Fire Department

Division of Community Risk Management

inspection@cityoflacrosse.org (P) 608.789.7530 (F) 608.789.7589
<http://www.cityoflacrosse.org/your-government/departments/fire-department>



7/1/2024

BF LA CROSSE LIMITED PARTNERSHIP
326 WEST AVE N
LA CROSSE, WI 54601

RE: An appeal regarding the requirement to provide a 8.915' set back from the front property line at 1018 Badger St, La Crosse, Wisconsin.

Dear BF La Crosse Limited Partnership,

We have received the permit application to construct a new single-family dwelling that does not meet the minimum requirements set forth in the Municipal Code of Ordinances of the City of La Crosse (Code) regarding setbacks from the front property line.

The project as proposed is in direct violation of the following subparagraph of the Code:

Sec. 115-142. - R-1 Single Family Residence District Regulations.

(2) Front yards. On every lot in the Residence District, there shall be a front yard having a depth of not less than 25 feet, provided that where lots comprising 40 percent or more of the frontage on one side of a block are developed with buildings, **the required front yard depth shall be the average of the front yard depths of the two adjacent main buildings**, or if there is only one adjacent main building the front yard depth of said main building shall govern; provided further that this regulation shall not be so interpreted as to require a front yard depth of more than 25 feet in any case. The entire front yard shall be graded and sodded or seeded in a manner which will produce an acceptable lawn excepting such.

Therefore, if upon consideration of all of the facts surrounding this appeal in a public hearing, the Board of Zoning Appeals determines that this appeal meets all of the criteria established by the Legislature of the State of Wisconsin, as interpreted by the Supreme Court of the State of Wisconsin for the granting of variances, the Board of Zoning Appeals would have to grant a variance of **2'1-1/2"** to the required **8.915'** set back to the front property line for this project to proceed as proposed.

Sincerely,

Kelsey Hanson

Kelsey Hanson

Building Inspector