



City of La Crosse, Wisconsin

City Hall
400 La Crosse Street
La Crosse, WI 54601

Meeting Agenda - Final

Board of Public Works

Tuesday, January 20, 2026

10:00 AM

Council Chambers
City Hall, First Floor

The Board of Public Works meeting is open for in-person attendance and will also be conducted through video conferencing. The meeting can be viewed by visiting the Legislative Information Center (<https://cityoflacrosse.legistar.com/Calendar.aspx>) and clicking on the video link to the far right in the meeting list.)

Call to Order

Roll Call

Shaundel Washington-Spivey, Tamra Dickinson, Erin Goggin, Matt Gallager, Andrea Trane.

Approval of Minutes

Minutes from January 12, 2026.

Agenda Items:

- [26-0056](#) Request to approve Kwik Trip Kitchens - La Crosse Plant Industrial Wastewater Discharge Permit.
- [26-0053](#) Construction Contract Change Orders.
- [26-0064](#) Construction Contract Final Payments.

Adjournment

Notice is further given that members of other governmental bodies may be present at the above scheduled meeting to gather information about a subject over which they have decision-making responsibility.

NOTICE TO PERSONS WITH A DISABILITY

Requests from persons with a disability who need assistance to participate in this meeting should call the City Clerk's office at (608) 789-7510 or send an email to ADACITYCLERK@CITYOFLACROSSE.ORG, with as much advance notice as possible.



City of La Crosse, Wisconsin

City Hall
400 La Crosse Street
La Crosse, WI 54601

Text File

File Number: 26-0056

Agenda Date: 1/20/2026

Version: 1

Status: Agenda Ready

In Control: Board of Public Works

File Type: Request

Agenda Number:

INDUSTRIAL WASTEWATER DISCHARGE PERMIT

In accordance with the provisions of chapter NR 211 Wisconsin Administration Code (Department of Natural Resources general pretreatment requirements), Federal pretreatment regulations 40 CFR 403, and Chapter 46 Article III Division 2 of the Municipal Code of Ordinances of the La Crosse (hereinafter, City Ordinance Chapter 46)

**Kwik Trip Kitchens
2200 Palace Street
La Crosse, WI 54601**

Is hereby authorized to discharge industrial wastewater from the above identified facility into the La Crosse Wastewater Treatment System pursuant to the effluent limitations, monitoring requirements, and other conditions set forth in this permit.

Compliance with this permit does not relieve the permittee of its obligation to comply with any or all applicable pretreatment regulations, standards, or requirements under Local, State, and Federal laws; including any such regulations, standards, requirements, or laws that may become effective during the term of this permit.

Non-compliance with any term or condition of this permit constitutes a violation of City Ordinance Chapter 46. This permit is issued to the specific user identified above and shall not be reassigned, transferred, or sold to another user or to a different address.

The terms and conditions of this permit may be amended during the life of this permit, as limitations or requirements identified in City Ordinance Chapter 46 are modified or changed.

C. This permit shall become effective on the date of signature and shall expire at midnight on February 1st, 2031.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after the expiration date, the permittee shall file for reissuance of this permit in accordance with the requirements of City Ordinance Chapter 46, at least 90 days prior to the expiration date.

La Crosse Wastewater Treatment Facility

By _____
Jared Greeno (Superintendent)

Dated This _____ Day of _____, Year _____

PART 1 – Specific Applicable Effluent Limitations

A review of current wastewater data indicates Kwik Trip Kitchens will be unable to consistently comply with the standards established in City Ordinance Chapter 46. Kwik Trip Kitchens will be allocated the conditions and limitations below:

A. Conditions

1. That the manhole(s) used for sampling be cleaned and maintained so that flow proportional samples can be taken, to accurately reflect the volume and strength of Kwik Trip Kitchens process discharge(s).
2. Sample Location: There are two discharge manholes for this site. West manhole 8-inch pipe, East manhole 6-inch pipe.
3. That all reasonable efforts be made to reduce the pollutant loading to the La Crosse Wastewater Treatment System. Including but not limited to:
 - a. Water use reduction/recycle
 - b. Chemical reduction/alternatives
 - c. Improved process controls
 - d. Spill control measures/procedures
 - e. Regular preventive maintenance/clean-up

B. Limitations

Table 1

| Parameter | Limitations |
|---------------------------------|-----------------|
| Biochemical Oxygen Demand (BOD) | 5000 mg/L |
| Total Suspended Solids (TSS) | 2000 mg/L |
| FOG (Fats, Oil, & Grease) | 200 mg/L |
| PH | 6.0 - 11.0 s.u. |
| Phosphorus, Total | 75 mg/L |

C. Any violation of the above limits will be met with enforcement, including, but not limited to:

1. Issuance of Notices of Violations (NOVs) and Compliance Orders
2. Administrative penalties or forfeitures
3. Legal Action or monetary penalties
4. Termination of sewer and/or water service, permit revocation.

PART 2 - MONITORING AND REPORTING REQUIREMENTS

Section 1 - General Requirements

- A. Special Conditions: If this industry has chemical, mixing, storage, dilution, or rinse tanks, etc., which are periodically dumped, a logbook showing at a minimum: the date, time (start-finish), quantity, and pH of the dump, shall be maintained for pretreatment inspection purposes.
- B. Slug Control Plan: A slug control plan is required and is on file at the Wastewater Utility
- C. Report Signature: All monitoring reports shall be signed and validated by a principal executive officer or designee (see signatory requirements in PART 4, Section 13 of this permit).
- D. Solvent Management Plan: A specific solvent management plan is not required.

Section 2 - Additional Reports

A. Non-compliance

If Industry self-monitoring or City compliance monitoring (sampling done by The City) reveals a violation of any discharge limitations specified herein, the industry shall report said violation to the City of La Crosse POTW within 24 hours of becoming aware of the violation. The City POTW will notify permittee of any compliance sampling violations. The industry shall repeat the sampling (within 21 days) until two (2) consecutive samples show that the non-compliance has been corrected. Additionally, a written report indicating the results of any required repeat sampling episodes and analysis shall be submitted within 30 days of becoming aware of the initial violation. Additional monitoring episodes due to non-compliance will not be counted in fulfilling the obligation of required sampling.

B. Accidental Discharge - City Ordinance Chapter 46 Article III Div. 2 Sec.46-112

If, for any reason, the permittee discharges prohibited substances caused by spills, slugs, accidental discharges, etc., the permittee shall immediately notify personnel at the La Crosse Wastewater Treatment Plant at **(608) 780-3554**.

The permittee shall identify the time of discharge, the type of substance, the quantity, the corrective action being taken, and the phone number of the person in charge of remedial action.

A written report shall be mailed to the Industrial Pretreatment Section within five (5) days of the occurrence, detailing the reasons for, and makeup of, the offending discharge and the permittee's remedial efforts, and what measures will be taken to ensure that the spill, slug, or accidental discharge will not be repeated in the future.

PART 3 - GENERAL PROHIBITED DISCHARGE STANDARDS**Section 1 - City of La Crosse Pretreatment Standards**

No person shall discharge, deposit, or allow to be discharged or deposited into the wastewater treatment system, any wastewater which violates the prohibited discharge standards found in City Ordinance Chapter 46 Article III Division 2 46-109 (2) and briefly described as follows:

- A. Wastewater which has a closed cup flashpoint of less than 60 degrees Centigrade or 140 degrees Fahrenheit using test methods specified in 40 CFR 261.21.
- B. Solid or viscous waste, or wastes that may become solid or viscous in the sewer, and may interfere with the natural flow in a sewer or make excessive sewer cleaning necessary
- C. Garbage that has not been ground or reduced in size to such a degree that all particles are less than one-half inch (1/2") in any dimension
- D. Noxious or malodorous liquids, solids, or gases
- E. Waste may cause corrosion or deterioration of the wastewater treatment plant system. Waste discharged to the treatment plant system shall have a pH value of 6.0 to 9.0 Standard Units at the point of introduction
- F. Fat, wax, oil, and/or grease which may solidify and/or become viscous at temperatures between 32- and 149-degrees Fahrenheit
- G. Radioactive waste and/or isotopes
- H. Substances not removable by the wastewater treatment process which may cause discoloration, opacity, and/or foaming of the wastewater treatment plant effluent or its residues.
- I. Wastewater with a temperature below 40 nor above 104 degrees Celsius
- J. Unpolluted water including, but not limited to, non-contact cooling water, rainwater, river water, or ground water which may increase the hydraulic loading of the wastewater treatment plant.
- K. Slug loads causing interference with wastewater treatment plant system.
- L. Wastewater containing toxic pollutants.
- M. Solids, solids, or gases which may cause the Wastewater Treatment Plant effluent or treatment residues, sludges, or scum to be unsuitable for reclamation or disposal or interfere with the reclamation or disposal process or processes ordinarily employed, including causing a reduction in the allowable land application rate or allowable land application site life by more than ten percent (10%).

PART 3 - continued

N. Liquids, solids, or gases which are likely to cause the Wastewater Treatment Plant to violate WPDES standards.

O. Any trucked or hauled pollutant, except at discharge points designated by the POTW.

P. Wastewater discharges, except as authorized by the Board of Public Works, in mass discharge quantities or concentrations exceeding the following:

| Pollutant Parameter | Limitation |
|----------------------------------|------------|
| Biochemical Oxygen Demand (BOD) | 350 mg/L |
| Chemical Oxygen Demand (COD) | 500 mg/L |
| Total Suspended Solids (TSS) | 325 mg/L |
| Fats, Waxes, Oil, & Grease (FOG) | 100 mg/L |
| Phosphorus (P) | 7mg/L |
| Ammonia (NH3) | 40mg/L |

1. The above table is the domestic strength limits for wastewater discharged in La Crosse. Any results exceeding these limits are subject to surcharge billing.
2. Kwik Trip Kitchens will have a fixed surcharge, billed quarterly. Surcharge rates were calculated using the average result from trial sampling done from 2023-2025. The surcharge is as follows:
 - a. BOD: $(636.3 - 350 \text{ mg/L}) \times 8.34 \times 8.550 \text{ MG} = \mathbf{20415 \text{ pounds}}$
 - i. Total BOD Surcharge = **\$6328.65**
 - b. TSS: $(198 - 325 \text{ mg/L}) \times 8.34 \times 8.550 \text{ MG} = \mathbf{0 \text{ pounds}}$
 - i. Total TSS Surcharge = **\$0.00**
 - c. Phosphorus: $(16.8 - 7 \text{ mg/L}) \times 8.34 \times 8.550 \text{ MG} = \mathbf{699 \text{ pounds}}$
 - i. Total Phosphorus Surcharge = **\$7164.75**
 - d. Ammonia: $(1.129 - 40 \text{ mg/L}) \times 8.34 \times 8.550 \text{ MG} = \mathbf{0 \text{ pounds}}$
 - i. Total Ammonia Surcharge = **\$0.00**
3. Rates reviewed in 2025
 - a. BOD: **\$0.310** per pound of BOD
 - b. TSS: **\$0.400** per pound of TSS
 - c. Phosphorus: **\$10.25** per pound of phosphorus
 - d. Ammonia: **\$0.400** per pound of ammonia
4. Total quarterly surcharge for Kwik Trip Kitchens: **\$13,493.40**

PART 3 - continued

Q. Process wastewater containing pollutants exceeding the following concentrations as established on a continuous twenty-four (24) hour flow proportional basis or lesser period if process wastewater is discharged for less than twenty-four (24) hours in an average day of operation:

LIMITS

| Pollutant Parameter | Max. mg/L |
|---------------------|-----------|
| Arsenic | 0.45 |
| Cadmium | 0.69 |
| Chromium | 2.77 |
| Copper | 2.07 |
| Cyanide | 0.66 |
| Lead | 0.60 |
| Mercury | 0.0002 |
| Nickel | 1.91 |
| Zinc | 2.61 |

Section 2 – Other Conditions City Ordinance Chapter 46

In addition to the general prohibited discharge standards established in City Ordinance Chapter 46, no person shall discharge or cause to be discharged or deposited any wastewater or effluent which does not conform to pretreatment standards established by the Environmental Protection Agency or the Wisconsin Department of Natural Resources. Pretreatment limits shall minimally include applicable national categorical pretreatment standards for new and existing sources set out in 40 CFR, subchapter n, PARTS 401 through 471 inclusive. Wastewater, or effluent including domestic, commercial, and industrial waste, shall not contain any substance which is in violation of any State, Federal, or Local pretreatment or other discharge standards.

A. Compliance with categorical pretreatment standards - all users (existing sources or new sources) who are subject to categorical standards shall meet the compliance deadlines as outlined in Federal or State regulations.

B. Concentration and mass limits for categorical users - the control authority may, for ease of operation, convert mass limits to concentration limits. The applicable Federal or State regulations will apply.

C. User shall annually review operations to see if there are alternative cleaning, painting, machining, plating, etching, etc., which would provide opportunity for waste reduction.

Section 3 – EPA Categorical Pretreatment Standards

The permittee identified on page 1 of this permit does not discharge any wastewater, which is subject to regulation by EPA categorical pretreatment standards.

PART 4 - GENERAL CONDITIONS

In addition to compliance with PARTS 1, 2 and 3, this permit is issued conditioned upon compliance with the following general conditions.

Section 1- Fees

City Ordinance Chapter 46 Article III Div. 2 Sec. 46-110 (g); the permittee shall pay annual or quarterly fees based on the following:

- A. Annual Administrative: Unit Cost x Fee Units
- B. Monitoring Charge: Personnel and equipment charges for scheduled City compliance monitoring are included in the administrative costs.
- C. Laboratory Analysis Charges: Analysis charges for samples collected for compliance monitoring will be billed to the industry for the constituents analyzed by the contract laboratory.
- D. Extraordinary Charges: Any extraordinary charges incurred due to non-compliance will be billed separately to the industry.

Section 2 - Admission to Property

City Ordinance Chapter 46 Article III Div. 2 Sec. 46 -112(g) Whenever it shall be necessary for the purposes of this permit, the board or its duly appointed representatives, upon presentation of credentials, may enter upon any property or premises of the permittee at reasonable times, either scheduled or unscheduled.

Section 3 - Modification or Revision

City Ordinance Chapter 46 Article III, Sec. 46-110(c, d); The terms and conditions of this permit are subject to change during the life of the permit as provided in City Ordinance Chapter 46

Section 4 - Severability or Conflict

City Ordinance Chapter 1 Sec. 1-8 The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected.

PART 4 - continued

Section 5 - Notice of Intent

City Ordinance Chapter 46 Article III, Div.2 Sec. 46-110 (d) The permittee shall apply for permit modification prior to the introduction of any changed wastewater into the La Crosse Wastewater Treatment System. In addition, according to 40 CFR 403.12 (j) the permittee shall promptly notify the POTW in advance of any substantial change in the volume or character of pollutants in their discharge, including the listed or characteristic hazardous wastes for which the permittee has submitted initial notification under 40 CFR 403.12 (p).

Section 6 - Enforcement, Appeal & Penalties

City Ordinance Chapter 46 Article III Div. 2 Sec. 46-108 Whenever it shall be necessary for the purposes of this permit, the board, or its duly appointed representatives, upon presentation of credentials, may enter upon any property or premises of the permittee at reasonable times, either scheduled or unscheduled Any permittee who has violated or is in violation of a City discharge permit, or who willfully or negligently fails to comply with any provisions of a City discharge permit, or who knowingly makes any false statement, representation or certification, or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method, shall be subject to the enforcement provisions of City Ordinance Chapter 46 Div. 2 Sec. 46-108 including termination, fines and/or civil penalties.

Section 7 – Confidentiality

City Ordinance Chapter 46 Article III Div. 2 Sec. 46-115 Except for information determined to be confidential in City Ordinance Chapter 46, all reports required by this permit shall be available for public inspection at the Wastewater Treatment Plant, Isle La Plume, under the supervision of pretreatment personnel.

Section 8 - Records Retention

City Ordinance Chapter 46 Article III Div. 2 Sec. 46-111(b) The permittee shall retain and preserve for no less than seven (7) years any records, books, documents, memoranda, reports, correspondence, and all summaries thereof, relating to monitoring, sampling, and chemical analysis made by or on behalf of a permittee in connection with the permittee's discharge. In addition, the permittee shall adhere to all other stipulations made under City Ordinance Chapter 46 Article III Div.2 Sec. 46-111

Section 9 - Dilution

City Ordinance Chapter 46 Article III Division 2 Sec.46-112(f). The permittee shall not increase the use of potable or process water in any way, nor mix separate waste streams for the purpose of diluting a discharge as a partial or complete substitute for adequate treatment to achieve compliance with the standards set forth in this permit.

PART 4 – continued**Section 10 – Bypass**

40 CFR 403.17 The permittee shall not intentionally divert any waste stream from any portion of the permittee's pretreatment facility. There are certain conditions where a bypass may be unavoidable; these conditions are set forth in 40 CFR 403.17. The control authority may approve an anticipated bypass after considering its adverse effects.

Section 11 - Discharge of Hazardous Waste

40CFR 403.12 (p) The permittee shall notify the POTW, the EPA regional waste management division director, and state hazardous waste authorities in writing of any discharge into the POTW of a substance, which, if otherwise disposed would be a hazardous waste under 40 CFR Part 261. The notification shall be in accordance with 40 CFR 403.12 (p).

Section 12 - Signatory Requirements

All reports required by this permit shall be signed by one of the following:

1. A president, secretary, treasurer, vice-president in charge of a principal business function or any other person who performs similar policy or decision-making functions for the corporation.
2. The manager of one or more manufacturing facilities provided the manager is authorized to make decisions which govern the operation of the facility, make major capital investment recommendations, initiate and direct comprehensive measures to assure long-term compliance with environmental laws, can ensure the necessary systems are established to gather complete and accurate information for the report and where authority to sign documents has been delegated to the manager according to the corporation's procedures; or a responsible corporate officer of the permittee, or designee, as outlined in 40 CFR, 403.12 (1) and amendments thereto, written authorization for the designee (position or individual) shall be properly signed and on file at the La Crosse Wastewater Treatment Facility, Industrial Pretreatment Section, prior to or simultaneous with submission of the required reports. All required reports shall include the following certification.

PART 4 – continued**Section 13 — Total Toxic Organic Certification**

Total Toxic Organics is keeping track of all solvents delivered to a facility, their storage, use and disposal. This includes keeping spent solvents segregated from other process wastewaters to maximize the value or recoverable solvents, to avoid contamination of other segregated wastes, and to prevent the discharge of toxic organics to any wastewater collection system or the environment.

TOXIC ORGANICS CERTIFICATION

Based on my inquiry of the person or persons directly responsible for managing compliance with the pretreatment standard for TTO, I certify that to my knowledge and belief, no discharge of concentrated toxic organics into the wastewater has occurred since filing the last discharge monitoring report. I further certify that this facility is implementing the solvent management plan submitted to the City Wastewater Utility.

REPORT CONTENT CERTIFICATION

I further certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete including the possibility of fine and imprisonment for knowing violations. I am aware that there are significant penalties for submitting false information,

BY _____

TITLE _____

DATED _____

Reporting Address

All reports should be made to:

La Crosse Wastewater Utility
Industrial Pretreatment Section
905 Joseph Houska Drive
La Crosse WI 54601

Telephone Number (608) 789-7343



City of La Crosse, Wisconsin

City Hall
400 La Crosse Street
La Crosse, WI 54601

Text File

File Number: 26-0053

Agenda Date: 1/20/2026

Version: 1

Status: Agenda Ready

In Control: Board of Public Works

File Type: General Item

Agenda Number:

CONTRACT CHANGE ORDER

No. 2

Date 11/26/2025

EDF # 25-050

Contract No. 9551420 for the following public work: 2025 Carroll Park Improvements between All American Lumber, Inc. and the City of La Crosse, dated 03/06/2025, is hereby changed in the following particulars, to-wit:

The following specific work is hereby eliminated from such contract:

N/A


The following specific work is hereby added to such contract:

Add insulated walls and ceiling, FRP interior finish, additional electrical.

By virtue of such changes in the contract, the following revisions shall be made:


| | |
|----------------------------------------------------|----------------------------|
| Contract ----- | <u>\$500,374.43</u> |
| Contingency ----- | <u>\$75,056.16</u> |
| Net Previous Change Orders ----- | <u>\$4,148.15</u> |
| Decrease by eliminations (this C.O.) ----- | <u>\$(0.00)</u> |
| Increase by additions (this C.O.) ----- | <u>\$29,500.00</u> |
| Net Deductions or Additions (Strike out one) ----- | <u>\$33,648.15</u> |
| Revised Contract Total ----- | <u>\$534,022.88</u> |

Matthew Buswell
NAME OF CONTRACTOR


CONTRACTOR SIGNATURE


BOARD OF PUBLIC WORKS

I HEREBY CERTIFY that there are sufficient funds in the treasury to meet the liability assumed by the foregoing addenda to contract, or that provision has been made to pay the liability that will accrue thereunder. (WS 62.15-12; 62.09-10-f)

Signed by:

B7509F2EE0E24E5

Budget Analyst

Signed by:


A93F306A40954A6...

Controller

CONTRACT CHANGE ORDERNo. 3Date 01/08/2026EDF # 25-050

Contract No. 9551420 for the following public work: 2025 Carroll Park Improvements between All American Lumber, Inc. and the City of La Crosse, dated 03/06/2025, is hereby changed in the following particulars, to-wit:

The following specific work is hereby eliminated from such contract:

N/A

The following specific work is hereby added to such contract:

Add coved base trim.

By virtue of such changes in the contract, the following revisions shall be made:

| | |
|----------------------------------------------------|----------------------------|
| Contract----- | <u>\$500,374.43</u> |
| Contingency----- | <u>\$75,056.16</u> |
| Net Previous Change Orders----- | <u>\$33,648.15</u> |
| Decrease by eliminations (this C.O.)----- | <u>\$(0.00)</u> |
| Increase by additions (this C.O.) ----- | <u>\$2,262.00</u> |
| Net Deductions or Additions (Strike out one) ----- | <u>\$35,910.15</u> |
| Revised Contract Total ----- | <u>\$536,284.58</u> |

Matthew Buswell
NAME OF CONTRACTOR



CONTRACTOR SIGNATURE

BOARD OF PUBLIC WORKS

I HEREBY CERTIFY that there are sufficient funds in the treasury to meet the liability assumed by the foregoing addenda to contract, or that provision has been made to pay the liability that will accrue thereunder. (WS 62.15-12; 62.09-10-f)

Signed by:



B7509F2EE0F24E5...

Budget Analyst

Signed by:



A93F306A40954A6...

Controller



City of La Crosse, Wisconsin

City Hall
400 La Crosse Street
La Crosse, WI 54601

Text File

File Number: 26-0064

Agenda Date: 1/20/2026

Version: 1

Status: Agenda Ready

In Control: Board of Public Works

File Type: General Item

BOARD OF PUBLIC WORKS - MONTHLY ESTIMATE

| | | | |
|-------------------|------------------------------------------------|---------------------------|---------------------|
| Contractor | Fowler & Hammer, Inc. | Estimate Number | FINAL |
| | 313 Monitor Street, La Crosse, WI 54603 | | #3 February |
| Contract | 2025 Sewer Utility Sidewalk Replacement | Resolution Number | 25-0036 |
| Date | February-26 | Contingency Amount | \$18,490.75 |
| EDF # | 25-013.02 | Contract Amount | \$184,907.50 |
| Job Number | PAVE-25-07 | | |

BOARD OF PUBLIC WORKS - MONTHLY ESTIMATE

| | | |
|------------|------------------------------------------------------------------|--------------------------------|
| Contractor | Fowler & Hammer, Inc. 313 Monitor Street, La Crosse, WI 54603 | FINAL |
| Contract | 2025 Sewer Utility Sidewalk Replacement | Estimate Number #3 February |
| Date | February-26 | Resolution Number 25-0036 |
| EDF # | 25-013.02 | Contingency Amount \$18,490.75 |
| Job Number | PAVE-25-07 | Contract Amount \$184,907.50 |

| Section Title | Line Item | Item Code | Item Description | Unit of Measure | Quantity | Unit Price | Total |
|----------------------------------------------------------------|-----------|-----------|-----------------------------------------|-----------------|----------|------------|--------------|
| | | | | | | | |
| | | | Current Payment is for 2025 Work | | | | |
| | | | | | | | |
| | | | | | | | |
| Total Completed | | | | | | | \$188,726.06 |
| Less 0% Retainage | | | | | | | \$0.00 |
| Amount due on Contract of total amount of work to date: | | | | | | | \$188,726.06 |

Signed by: 1/14/2026 20 Total Previous Estimates \$67,383.12
 Audited *David Tauscher*
 Signed by:
 B7509F2EE0F24E5
 COMPTROLLER *Chadwick Hawkins*
 A93F306A40954A6...

RESOLUTION

RESOLVED: That an order be drawn in favor of Fowler & Hammer, Inc..... for the sum of **\$121,342.94**
 the same being payment of the estimate for the 2025 Sewer Utility Sidewalk Replacement

Respectfully Submitted,
COUNCIL COMMITTEE

APPROVED BY BOARD OF PUBLIC WORKS

BOARD OF PUBLIC WORKS - MONTHLY ESTIMATE

| | | | |
|-------------------|------------------------------------------------|---------------------------|---------------------|
| Contractor | Fowler & Hammer, Inc. | Estimate Number | FINAL |
| | 313 Monitor Street, La Crosse, WI 54603 | | #3 February |
| Contract | 2025 Sewer Utility Sidewalk Replacement | Resolution Number | 25-0036 |
| Date | February-26 | Contingency Amount | \$18,490.75 |
| EDF # | 25-013.02 | Contract Amount | \$184,907.50 |
| Job Number | PAVE-25-07 | | |

BOARD OF PUBLIC WORKS - MONTHLY ESTIMATE

| | | |
|------------|------------------------------------------------------------------|--------------------------------|
| Contractor | Fowler & Hammer, Inc. 313 Monitor Street, La Crosse, WI 54603 | FINAL |
| Contract | 2025 Sewer Utility Sidewalk Replacement | Estimate Number #3 February |
| Date | February-26 | Resolution Number 25-0036 |
| EDF # | 25-013.02 | Contingency Amount \$18,490.75 |
| Job Number | PAVE-25-07 | Contract Amount \$184,907.50 |

| Section Title | Line Item | Item Code | Item Description | Unit of Measure | Quantity | Unit Price | Total |
|---------------|-----------|-----------|----------------------------------------------------------------|-----------------|----------|------------|--------------|
| | | | | | | | |
| | | | Current Payment is for 2025 Work | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | Total Completed | | | | \$188,726.06 |
| | | | Less 0% Retainage | | | | \$0.00 |
| | | | Amount due on Contract of total amount of work to date: | | | | \$188,726.06 |

Signed by: 1/14/2026 20 Total Previous Estimates \$67,383.12
 Audited *David Tauscher* Signed by: Estimate No. #3 February \$121,342.94
 B7509F2EE0F24E5
 COMPTROLLER *Chadwick Hawkins* A93F306A40954A6...

RESOLUTION

RESOLVED: That an order be drawn in favor of Fowler & Hammer, Inc..... for the sum of **\$121,342.94**
 the same being payment of the estimate for the 2025 Sewer Utility Sidewalk Replacement

Respectfully Submitted,
COUNCIL COMMITTEE

APPROVED BY BOARD OF PUBLIC WORKS

CONTRACT CHANGE ORDERNo. 3Date 01/08/2026EDF # 25-050

Contract No. 9551420 for the following public work: 2025 Carroll Park Improvements between All American Lumber, Inc. and the City of La Crosse, dated 03/06/2025, is hereby changed in the following particulars, to-wit:

The following specific work is hereby eliminated from such contract:

N/A

The following specific work is hereby added to such contract:

Add coved base trim.

By virtue of such changes in the contract, the following revisions shall be made:

| | |
|----------------------------------------------------|----------------------------|
| Contract----- | <u>\$500,374.43</u> |
| Contingency----- | <u>\$75,056.16</u> |
| Net Previous Change Orders----- | <u>\$33,648.15</u> |
| Decrease by eliminations (this C.O.)----- | <u>\$(0.00)</u> |
| Increase by additions (this C.O.) ----- | <u>\$2,262.00</u> |
| Net Deductions or Additions (Strike out one) ----- | <u>\$35,910.15</u> |
| Revised Contract Total ----- | <u>\$536,284.58</u> |

Matthew Buswell
NAME OF CONTRACTOR



CONTRACTOR SIGNATURE

BOARD OF PUBLIC WORKS

I HEREBY CERTIFY that there are sufficient funds in the treasury to meet the liability assumed by the foregoing addenda to contract, or that provision has been made to pay the liability that will accrue thereunder. (WS 62.15-12; 62.09-10-f)

Signed by:



B7509F2EE0F24E5...

Budget Analyst

Signed by:



A93F306A40954A6...

Controller