

Installation of gas main will maintain separation from utilities.
> or = 3' from hydrants, valves, light bases
> or = 5.5' from manholes, catch basins & inlets
> or = 7' from water-main

Replace 2" PE main with 2" PE along the edge of the street. Tie in to existing 2" PE at 2423 Chase St.

Retire existing steel main from 2506 Chase St to 2418 Sunrise Dr.

Install 2" PE main from main along Sunrise Dr to tie in to the steel main located at 2506 Chase St.

Replace 2" PE main with 2" PE along the edge of the street. Tie in to existing 2" PE along Glendale Ave at 2424 Glendale Ave.

