



NOTES:
 BUILDING: 15,480 SF
 CONCRETE: 1,000 SF
 PAVEMENT: 11,970 SF
 PERVIOUS: 4,000 SF
 TOTAL: 32,450 SF

POST CONSTRUCTION STORM WATER REQUIREMENTS:
 1. 80% OF PARKING LOT RUNOFF SHALL DRAIN TO INFILTRATION DEVICE
 2. MINIMUM INFILTRATION AREA 10% OF PARKING AREA—1,200 SF
 3. 100% INFILTRATION OF 2-YEAR STORM

PRELIMINARY STORM WATER BMP SELECTION
 1. 1,940 SF BIO-FILTER AREA
 2. 500 SF PERVIOUS PAVING

