

See Sheet 2

Sheet 3 of 3

All New 2" duct will be placed Minimum 24" from any existing Utility and at a Minimum Depth of 30"

Sheets Not to Scale

Dairyland Power
3200 East Ave. S
PID 5942088

Proposed 2" Duct
8' from Back of Curb
330' Vault to Vault

Gas 6" Back from Curb

Proposed 2" Duct
3' Back from Curb

Water 10' Back from Curb

Existing
Vault

3439 East Ave. South