


**3519 MORMON COULEE RD**  
 T&TO 1"PE SERVICE W/2600EFV  
 I-1000METER AND LOOP@2PSI  
 R-800METER AND LOOP WORK WITH LOCAL  
 OPERATIONS FOR COORINATING OUTAGE AND  
 METER EXCHANGE

NEXT MAP 3A

**WORK ORDER 111102677**  
 WARD AVE-21ST PL S. MAIN RENEWAL/PRESSURE CHANGE  
 DESIGNER ED PRZYTARSKI 608-780-0151  
 ENGINEER JIM FLANAGAN 715-577-0418  
 INSTALL 2"MDPE GAS MAIN RETIRE 2"STEEL & 3"STEEL MAIN  
 RENEW SERVICES (SEE INDIVIDUAL SERVICE MAPS FOR  
 SERVICE RENEW WORK ORDER #'S)  
 T&TO SERVICES AS NEEDED(ADDRESS NUMBERS ARE  
 HIGHLIGHTED YELLOW)



**RETIRE 2"STEEL & 3"STEEL MAIN**  
 (BLUE LINED IS RETIRE)

**S6, S34, S45--INSTALL 2"MDPE GAS MAIN**  
 (YELLOW LINED IS INSTALL)

**P32-INSTALL 2X2X2 BF FULLFLOW TEE**

SEE DETAIL MAP 7 FOR TIE-IN

**P43-INSTALL 2"PE**  
**BALL VALVE #225127**

**TEST & TIE-OVER SERVICES:**  
 WO 111102677-  
 3607 MORMON COULEE RD-5/8"PE W/450EFV  
 COMMERCIAL CUSTOMER  
 3519 MORMON COULEE RD-1"CTS W/2600EFV  
 COMMERCIAL CUSTOMER METER EXCHANGE  
 WORK WITH LOCAL OPERATING.  
 2115 VICTORY ST-5/8"PE W/450EFV  
 2919 21ST PL S.-5/8"PE W/450EFV  
 2915 21ST PL S.-5/8"PE W/450EFV

**SERVICE RENEWALS:SEE INDIVIDUALWO #'S:**  
 2124 VICTORY ST-5/8"PE W/450EFV  
 2123 VICTORY ST-5/8"PE W/450EFV  
 3625 MORMON COULEE RD-1"CTS W/775EFV  
 2945 21ST PL S.-5/8"PE W/450EFV  
 2933 21ST PL S.-5/8"PE W/450EFV  
 2929 21ST PL S.-5/8"PE W/450EFV  
 2923 21ST PL S.-5/8"PE W/450EFV

**P33-INSTALL 2X2HV**  
**TAPPING TEE**

**CANNOT DIG THE BLACKTOP**  
**ROAD WAY OF THE 2100**  
**BLOCK OF VICTORY ST.**  
**HIGHLIGHTED ABOVE.**

**P44-INSTALL 2X2X2BF**  
**FULLFLOW TEE**

**P46-INSTALL 2"PE BF CAP**

Request Number: **MAP 4A**  
 SP Number:  
 Segment:  
 UCR/..

Work Order Information	
Service Request #	000013524354
Design Number	000001147530
Designer/Planner ID	W72519
Designer/Planner Name	
Designer/Planner Ph #	
Manager Approval	

Joint Utility	
E:	G:
T:	C:

Design Location	
Division	La Crosse
County	La Crosse
City	LA CROSSE
Address	
T: 15N	R: 7W S: 16
Map #	1644650 WIS Permit :

Electric	
Feeder:	Voltage:
Phase:	Bkup Dev ID:

Gas	
System	Pressure
Size	Material
Dead End	

Work Order # :  
 Date: 01/31/2024  
 Sketch:  
 Scale: 1" equals 83'



**CONSTRUCTION USE ONLY**  
 NO CHANGES (BUILT AS DESIGNED)  
 CHANGES MADE AS INDICATED  
 (ALL URD MUST HAVE ACTUAL MEASUREMENTS FROM THE FIELD SITE)

RFO \_\_\_\_\_  
 FOREMAN \_\_\_\_\_ DATE \_\_\_\_\_  
 TEAM LEADER \_\_\_\_\_

DISCLAIMER: THERE ARE NO REPRESENTATIONS OR WARRANTIES (EXPRESS OR IMPLIED) ABOUT THE ACCURACY OF THIS PRINT. THIS PRINT IS PROVIDED WITH NO CLAIM AS TO PRINT COMPLETENESS, TIMELINESS, ACCURACY OF CONTENT OR USEFULNESS. STATE LAW REQUIRES ANYONE DIGGING, GRADING OR EXCAVATING TO OBTAIN A PRIOR FIELD LOCATE OF ALL UTILITIES; THIS PRINT DOES NOT DISCHARGE THIS REQUIREMENT OR ANY OTHER REQUIREMENT. THE COMPANY AND ITS AFFILIATES ASSUME NO LEGAL RESPONSIBILITY OR LIABILITY FOR THE RECIPIENT'S USE (OR ANY OTHER PARTIES' USE) OF THE PRINT, INCLUDING THE RECIPIENTS INTENDED PURPOSE IN USING THE PRINT. NO COMPANY EMPLOYEE OR OTHER PARTY HAS BEEN AUTHORIZED TO PROVIDE THIS PRINT FOR PLANNING OR ESTIMATING PURPOSES; RELY ON THIS PRINT AT YOUR OWN RISK. BY ACCEPTING THIS PRINT, THE RECIPIENT & ANY OTHER PARTY RECEIVING A COPY OF THE PRINT ACKNOWLEDGES AND AGREES TO THIS DISCLAIMER. For All Field Locates Call 811