

Holland, Michelle

From: McRoberts, Jason L <Jason.l.mcroberts@xcelenergy.com>
Sent: Thursday, August 21, 2025 10:49 AM
To: ZZ Engineer External
Cc: Lueck, Alex J; Johnson, Nicholas D
Subject: Excavation in River Point District
Attachments: City of La Crosse Permit Application Eagle Rest & Kraft.pdf

*** **CAUTION:** This email originated from an external sender. **DO NOT** click links or open attachments unless you recognize the sender and know the content is safe. ***

To All,

Xcel Energy was onsite this morning to pull wire in our existing conduit along Kraft Street and found that we are unable to get the rope through at 2 different locations. The first location is directly in the middle of the south crosswalk of Eagle Rest Rd and Kraft Street. The next location is under the sidewalk approximately 200' east of that intersection. I contacted Matt Gallagher on this subject and he told me to get this letter and an excavation permit to the engineers so it can be brought in front of the Public Works Board. Xcel Energy needs to be able to loop this wire because The Lofts (Rykey) are in the radial feed for Driftless. Driftless will have to be fed from the other direction when we are installing the transformer for The Lofts. Xcel Energy was out there this morning to install the wire from the last transformer in Driftless to the switchgear at the corner of Marsh Lane and Kraft Street (easement in SW corner) to create the loop feed. Please see below where the 2 areas that are conduit is damaged.



Thanks,

JASON MCROBERTS

Xcel Energy

Principal Designer, Electric Distribution
3215 Commerce St, La Crosse, WI 54603

P: 608-789-3689 C: 715-577-1132

E: jason.L.mcroberts@xcelenergy.com

[Message me on Teams](#)

[Call me on Teams](#)

Link: [FastApp](#)

Link: [Standard for Electric Installation and Use](#)

Link: [Site Readiness Checklist](#)

MAKING ENERGY WORK BETTER