

From: Will Kratt will.kratt@is-grp.com
 Subject: FW: Review Request: La Crosse Center Exhibits
 Date: Jul 10, 2018 at 5:31:55 PM
 To: Olson, Jessica olsonje@cityoflacrosse.org
 Cc: Kuhlman, Lewis kuhlmanl@cityoflacrosse.org

*** CAUTION: This email originated from an external sender. DO NOT click links or open attachments unless you recognize the sender and know the content is safe. ***

Jessica,

Per your request, below is the email from the WDNR saying that the project as proposed is an allowable use, and no study will be required.

Thanks!

Will Kratt PE

Associate Principal, Practice Group
 Leader

201 Main St. Suite 1020
La Crosse, WI 54601
 P: 608.789.2034
 C: 608.498.0940
will.kratt@is-grp.com



Architecture | Engineering | Environmental | Planning

From: Kuhlman, Lewis <kuhlmanl@cityoflacrosse.org>
Sent: Tuesday, July 10, 2018 2:07 PM
To: Will Kratt <will.kratt@is-grp.com>; Kevin Bills <Kevin.Bills@is-grp.com>
Subject: FW: Review Request: La Crosse Center Exhibits

Will and Kevin,

Good news - Michelle Hase says, "An overhang without any supports in the floodway and the bottom of the structure is above the floodplain elevation is an allowable use per NR116, and no study would be required."

Thank you,
 Lewis

From: Hase, Michelle M - DNR [<mailto:Michelle.Hase@wisconsin.gov>]
Sent: Tuesday, July 10, 2018 1:07 PM
To: Kuhlman, Lewis
Subject: RE: Review Request: La Crosse Center Exhibits

*** CAUTION: This email originated from an external sender. DO NOT click links or open attachments unless you recognize the sender and know the content is safe. ***

An overhang without any supports in the floodway and the bottom of the structure is above the floodplain elevation is an allowable use per NR116, and no study would be required.

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

Michelle Hase, P.E.

Phone: (262) 574-2127

michelle.hase@wi.gov

From: Kuhlman, Lewis [<mailto:kuhlmanl@cityoflacrosse.org>]
Sent: Tuesday, July 03, 2018 2:42 PM
To: Hase, Michelle M - DNR <Michelle.Hase@wisconsin.gov>
Subject: Review Request: La Crosse Center Exhibits

Michelle,

Could you please review the current Proposed B1 Concept for the La Crosse Center for compliance with floodplain regulations? In particular, the overhang into the floodway has been questioned. If possible, even a preliminary look before the Common Council meeting on 7/12 would be really helpful for people to make good decisions and votes. Please let me know if you need anything else.

Thank you,

Lewis Kuhlman, AICP, CFM | Environmental Planner

[City of La Crosse](#) | 400 La Crosse Street, La Crosse, WI 56401 | p [608-789-7361](tel:608-789-7361) | f [608-789-7318](tel:608-789-7318)

The information contained in this message may be privileged, confidential, and protected from disclosure. This message is intended solely for the intended recipient to whom it is addressed. Any review, retransmission, dissemination, distribution, copying, or other use is strictly prohibited. If you have received this email in error, please respond to the sender and delete the material from any computer and/or server.