

May 19, 2015

City of La Crosse Attn: Robert Haines 400 La Crosse Street La Crosse, WI 54601

RE: Well Pump Replacement

Dear Bob,

It was a pleasure to meet with you last week. As we discussed, the well pump motor is completely shorted out, and there appears to be another fused disconnect, prior to the starter disconnect, that also has a blown fuse. Since it appears the pumping equipment has been in service for 22 years, we would recommend replacing everything in the well. In addition, since the pump will be out, we would recommend brushing the screen with a bio-dispersant and chlorine to make sure the screen is clean prior to installation of the new permanent pumping equipment. This proposal is based on the work being performed, while we are in town working on Well No. 22.

Please review the following scopes of work and their associated costs for the project:

- 1. Load and mobilize to job site.
- 2. Set up and remove the existing pump from the well.
- 3. Brush well screen/casing and bail fill from bottom of well.
- 4. Surge well with surge block with 10 gallons bio-dispersant and 100 ppm chlorine.
- 5. Provide and install new 20HP Franklin motor and Grundfos 300GPM SS pump.
- 6. Provide and install 80 feet of 4-inch black drop pipe w/check valve.
- 7. Provide and install 87 feet of #8 3-wire w/ground submersible cable and airline.
- 8. Run pump to waste/test, until clear, over the top of the well casing.
- 9. Re-install pitless adaptor and reset pump on pitless.
- 10. Demobilize from job site.

.....Lump Sum: <u>\$ 10,960</u>

We trust you will find this correspondence to your understanding. Should you have any questions or concerns regarding this proposal, or if there is any other way we can be of assistance to your facility, please contact our offices at your earliest convenience. We appreciate this opportunity to provide you with this proposal, and look forward to the opportunity to provide the City of La Crosse expert service on this project.

Sincerely, MUNICIPAL WELL & PUMP

Marty Van Ells

Marty Van Ells Project Manager

C:\Users\Marty Van Ells\Desktop\Marty Shared\Proposals\Marty\Marty's Proposals 2015\La Crosse City Hall\La Crosse City Hall Well Pump Repairs_5-19-15 doc