

La Crosse Sanitary Sewer Utility

Industrial Pretreatment section

905 Joseph Houska Drive
La Crosse, WI 54601
Phone: (608) 789-7330

General Superintendent: Jared Greeno
Special Projects Coordinator: Erik Schell

Notice of Violation (NOV)

1. Discharger's Name: City Brewing Company, LLC 925 3 rd Street South La Crosse, WI 54601	2. Discharge Location : City Brewery's wastewater pretreatment facility.	3. Date/Period of Violation: 12/1/2024, 12/2/2024, 12/3/2024, 12/6/2024 4. Permit No: B-10-1285-4
---	---	---

5 Description of Violation – Discharge of high-strength waste (COD) from the City Brewery wastewater pretreatment plant is greater than 12,000 PPD. This is a violation of the Industrial Pretreatment Permit. P.2

- Provide a report of why exceedance occurred
- What will be done to alleviate this problem from recurring

Jared Greeno Superintendent WWTF – La Crosse SSU

Date

Notice of Violation

THE FOLLOWING INFORMATION SHALL BE COMPLETED BY PERMITTEE:

(1) Acknowledgement of Receipt of Notice of Violation*:

Authorized Representative-Permittee

Date

Title

(2) A written response is required from City Brewery Company, LLC by 12/30/2024 as described above.