



AA
A4
SECTION
 1/4" = 1' - 0"

KEY NOTES:

1. 8" 4000 PSI POURED CONCRETE FOUNDATION W/ #4 REBARS @ 24" O.C. EA WAY. 2" RIGID STYROFOAM INSUL. FULL HEIGHT, 1/2" X 12" A307 HEX HEADED ANCHOR BOLTS, 1" EMBEDMENT @ 4'-0" O.C.
2. 4000 PSI CONCRETE FOOTING W/ (2) RUNS OF 4" REBARS.
3. 5" 4000 PSI CONCRETE FLOOR W/ #4 RE BARS GRID 18" O.C. EACH WAY, CENTER IN SLAB, 6 MIL POLY VAPOR BARRIER.
4. 6" COMPACTED SAND OR GRANULAR BASE
5. 5" 4000 PSI PARKING LOT, #4 RE BAR GRID @ 18" O.C. EACH WAY
6. 2 X 6 STUDS @ 16" O.C., 1/2" STRUCTURAL PLYWOOD SHEATHING, TYVEK BLDG WRAP, VINYL SIDING, R-21 INSULATION.
7. METAL BUILDING LINER OVER 1/2" OSB INTERIOR WALL FINISH OVER 4 MIL VAPOR RETARDER
8. STEEL LINER PANEL AT CEILING OVER 6 MIL VAPOR BARRIER.
9. CONTINUOUS SOFFIT VENT, PREFINISHED METAL FASCIA.
10. CONTINUOUS RIDGE VENT.
11. 30 YEAR FIBERGLASS SHINGLES, ROOFING FELT, 1/2" STRUCTURAL ROOF SHEATHING.
12. ENGINEERED ROOF TRUSSES @ 2'0" O.C., REFER TO ROOF FRAMING PLAN FOR NOTES AND SPECIFICATIONS.
13. R40 BLOWN INSULATION.
14. ATTACH END OF TRUSS TO WALL W/ SIMPSON H25A CLIPS

I hereby certify the title, specification, or report was prepared by me or under my direct supervision and that I am a duly Registered Architect under the laws of the State of WISCONSIN.
 Number _____ Date _____
 This drawing is and will remain the property of the architect and any reproduction or use for any purpose specifically agreed upon purposes, without the prior written consent of the architect, is strictly prohibited.
 Information contained in these drawings was prepared for the specific site listed below. Use of these drawings for any other location or project is strictly prohibited without prior written consent of the architect.


MBA Architects, Inc.
 3823 Creekside Lane
 Holmen WI, 54636
 PH: 608-785-2160
 FAX: 608-785-2150
 E-mail: patrick@mbs-architects.com

CHEE'S AUTO SHOP

 LOT 2, AIRPORT INDUSTRIAL PARK

 AIRPORT ROAD
 LA CROSSE, WI 54603

FOR:

A & J CONSTRUCTION
 N3292 BOND ROAD
 LA CROSSE, WI 54601

ISSUE DATES:

 5/14/19

MBA CONTACT
PATRICK BROCKMAN
 (608) 785-2160

drawn by: **P. BROCKMAN** checked by:

THIS SHEET CONTAINS:

BUILDING SECTIONS

PROJECT NUMBER

SHEET NUMBER

A4