



City Brewing Company, LLC
925 South 3rd Street
La Crosse, WI 54601

Date: 9/24/2024

To: Jared Greeno,

I am pleased to write this letter to you about the compliance order that was given to City Brewery in April. At this time I believe we have met the compliance order requirements. Please see my responses below for the actions that were needed to be completed.

- 1.) Force Main Repair – was completed by the 2nd week of Sept. 2024 and the plant is operating in normal condition.
- 2.) Roof repairs to the reactor cover have been completed and we have added an H₂S neutralizer called Zee Zyme Sulfa-Scav that is fed to 4 blowers that shoot a mist across the reactor roof. If any H₂S finds its way out this product will neutralize it. We are also still working down two different paths of either putting in a new WWTP or installing a new floating cover. We will know the exact path before the end of 2024.
- 3.) An H₂S remediation report was provided and we have shown significant reduction in H₂S generation. We added a product called Cal-Nitro in Aug. that is being fed into the system before the equalization tank. This product is consumed before the sulfates in the water thus resulting in less H₂S generation. We have also added an additional product called Zee Zyme Bacilli-Solv which is bacteria that is put into the wastewater system before the equalization tanks. This product targets and consumes sulfates along with BOD and COD. This living product takes about 4 to 6 weeks to get fully established in the wastewater system. This product was put online Sept. 11th. With the work that has been completed at this time I believe we have met this requirement.
- 4.) For the H₂S numerical limit we are working with the City WWTP team and will be reviewing the new permit in October. We have been meeting monthly and will continue to make sure that we will be able to meet the permit limits.

The information provided should meet the requested actions. Please provide feedback on this once you have reviewed. If you need any clarity or any more information I will be happy to provide.

Sincerely,

Matthew Sweet

Plant Manager
City Brewery, LLC
925 3rd Street
La Crosse, WI 54601
920-585-4598
msweet@citybrewery.com