



Building a Better World
for All of Us®

March 10, 2022

RE: City of La Crosse
CCF Bank - 141 7th St. South
SEH No. 161151 14.00

Yuri Nasonovs
Engineer
Engineering Department
400 La Crosse St.
La Crosse, WI 54601

Dear Mr. Nasonovs:

As a follow-up to your request for additional information per the February 4, 2022 commercial design review meeting, here are clarifications to the design and a request to be exempted from requiring a storm water permit based on Chapter 105, Sec. 105-55:

- The project scope is to remodel the existing building
- The parking lot is in need of repair. To restore the surface, the proposed work is to pull up and remove the existing asphaltic surface and pave a new surface. The underlying base course will remain in place. We consider this work routine maintenance.
- The site will have less than a quarter acre of land disturbing activity
- Less than 400 cubic yards of excavation or fill
- Less than 300 feet of new utility or other open trench disturbance.
- No added impervious area.

If you would like to discuss this project further, or need additional information, please feel free to reach me at 608.498.4947 or jtomesh@sehinc.com.

Sincerely,

Jeremy Tomesh, PE
Project Manager
(Lic. WI))

JJT

\\sp-pz1.sehinc.com\pzprojects1\ael\clcitco\161151\city plan review\response 3.11.2022\storm water permit exemption request.docx

Engineers | Architects | Planners | Scientists

Short Elliott Hendrickson Inc., 329 Jay Street, Suite 301, La Crosse, WI 54601-4034

608.782.3161 | 888.908.8166 fax | sehinc.com

SEH is 100% employee-owned | Affirmative Action–Equal Opportunity Employer