



Legislation Details

File #:	2640	Version:	1	Name:	BOZA File 2640
Type:	Request for Variance	Status:		Status:	Approved
File created:	2/5/2020	In control:		In control:	Board of Zoning Appeals
On agenda:	2/19/2020	Final action:		Final action:	2/19/2020

Title: An appeal regarding the requirement that fill around the perimeter of a building shall be not less than one foot below the flood protection elevation and shall extend at least 15 feet beyond the limits of any structure at 710 George Street, La Crosse, Wisconsin.

Sponsors:

Indexes:

Code sections:

Attachments: 1. FP&BS Letter, 2. Variance Application, 3. Buffer Map, 4. 100-Foot Buffer List, 5. Signed Decision Sheet, 6. Affidavit of Publication

Date	Ver.	Action By	Action	Result
2/19/2020	1	Board of Zoning Appeals	GRANTED	Pass