

Luminaire Schedule						
Symbol	Qty	Label	Manufacturer	Description	Arrangement	LLF
	9	OW1	SLG	WME 12 G1 FSK-1250Lm-40K	Single	0.900
	11	OW2	RAB	SLIML @60W4000K @20DEG	Single	0.900
	1	OW3	RAB	SLIML @45W4000K @0DEG	Single	0.900

Calculation Summary						
Label	CalcType	Units	Avg	Max	Min	Avg/Min
25FT PAST LOT LINE AT 0FT 0IN	Illuminance	Fc	0.04	0.1	0.0	N.A.
PARKING LOT AND DRIVE	Illuminance	Fc	1.62	11.71	0.02	81.00
PROPERTY LINE 5FT ABOVE	Illuminance	Fc	0.04	0.5	0.0	N.A.

1. STANDARD REFLECTANCE OF 80/50/20 UNLESS NOTED OTHERWISE.
2. NOT A CONSTRUCTION DOCUMENT- FOR DESIGN PURPOSES ONLY.
3. STANDARD INDOOR CALC POINTS @ 30" AFF UNLESS NOTED OTHERWISE.
4. STANDARD OUTDOOR CALC POINTS @ GRADE UNLESS NOTED OTHERWISE.
5. EGRESS CALC POINTS @ 0'-0" AFF.
6. PHOTOMETRICS ARE ESTIMATED LIGHTING CALCULATIONS.
VIKING ELECTRIC ASSUMES NO RESPONSIBILITY FOR INSTALLED LIGHT LEVELS DUE TO FIELD CONDITIONS.
7. VIKING ELECTRIC NOT RESPONSIBLE FOR FINAL REVIEW OF CODE REQUIREMENTS.