



Compliance Certificate

Project 4 unit apartment

Energy Code: **2015 IECC**
 Location: **La Crosse, Wisconsin**
 Construction Type: **Multi-family**
 Project Type: **New Construction**
 Conditioned Floor Area: **4,918 ft²**
 Glazing Area **7%**
 Climate Zone: **6 (7491 HDD)**
 Permit Date:
 Permit Number:

Construction Site:
 Chase Street
 South Ave
 Lacrosse, WI 54601

Owner/Agent:
 Adam Hoffer
 Hoffer LLC
 1510 MADison St.
 Lacrosse, WI 54601
 608-785-5293
 ahoffer@uwlax.edu

Designer/Contractor:
 Steven Kumm
 Eskay Architecture
 520 Roders Club Rd
 Onalaska, WI 54650
 608-317-1565
 eskayarchitect@gmail.com

Compliance: Passes using UA trade-off

Compliance: **1.7% Better Than Code** Maximum UA: **530** Your UA: **521**

The % Better or Worse Than Code Index reflects how close to compliance the house is based on code trade-off rules. It DOES NOT provide an estimate of energy use or cost relative to a minimum-code home.

Envelope Assemblies

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	U-Factor	UA
Ceiling 1: Raised or Energy Truss	2,459	50.0	0.0	0.020	49
Wall 1: Wood Frame, 24" o.c.	4,018	21.0	0.0	0.056	200
Window 1: Vinyl/Fiberglass Frame:Double Pane with Low-E	281			0.290	81
Door 1: Solid	168			0.180	30
Floor 1: Slab-On-Grade:Unheated Insulation depth: 4.0'	235		10.0	0.684	161

Compliance Statement: The proposed building design described here is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed building has been designed to meet the 2015 IECC requirements in REScheck Version 4.7.0 and to comply with the mandatory requirements listed in the REScheck Inspection Checklist.

Name - Title

Signature

Date